



TOWN OF EAST GRANBY

INCORPORATED 1858

ENGINEERING DEPARTMENT
PO BOX 1858 9 CENTER ST
EAST GRANBY, CONNECTICUT 06026
PHONE 1-860-653-3444 FAX 1-860-653-4017

May 30, 2024

Ms. Robin Newton, AICP, CZEO
Town of East Granby
P.O. Box 1858
9 Center Street
East Granby, CT 06026

Re: Engineering Review Appl. #PZC 24-08
Galasso Quarry Permit Renewal
60 South Main Street
East Granby, CT

Robin:

We have reviewed the following regarding the above referenced application as submitted for review. We offer the following Engineering review comments.

1. Engineering Plans prepared for GALASSO HOLDINGS, LLC, 60 SOUTH MAIN STREET, EAST GRANBY, CONNECTICUT, DATED MAY 9, 2024. SCALE: AS NOTED, As prepared by Loureiro associates, Inc., to include the following sheets:
 - COVER SHEET, SHEET 1
 - TOPOGRAPHIC SURVEY (BY OTHERS), SHEET 2
 - TOPOGRAPHIC SURVEY (BY OTHERS), SHEET 3
 - OVERALL SITE AREA KEY MAP, SHEET 4
 - EXISTING CONDITIONS PLAN, SHEET 5
 - SITE PREPARATION PLAN, SHEET 6
 - SITE LAYOUT PLAN, SHEET 7
 - OVERALL GRADING PLAN, SHEET 8
 - DETAILED GRADING PLAN, SHEET 9
 - EXCAVATION PLAN, SHEET 10

- EXCAVATION CROSS SECTIONS, SHEET 11

ENGINEERING REVIEW COMMENTS:

1. Provide topography in the area of the existing sedimentation basins on the Existing Conditions Plan, sheet 5 and on the Overall Grading Plan, Sheet 8.
2. Provide Grading of proposed berm on the Overall Grading Plan, Sheet 8 and the Detailed Grading Plan, Sheet 9.
3. Provide a detailed Erosion & Sedimentation Control Measures Plan for all areas to be regraded and stabilized.
4. Provide a site-specific construction sequence.
5. Submit updated plans to the Town Engineer for review.

As submitted,
Thomas Grimaldi
Town Engineer