



BUILDING PERMIT APPLICATION

Town of East Granby

9 Center Street East Granby, CT 06026
Phone: (860) 653-3444 Fax: (860) 653-4017

Date: _____
Job Location (No. and Street) _____
Owner's Name: _____ Phone: _____
Owner's Address: _____
Town: _____ State: _____ Zip Code _____

Applicant's Name: First: _____ Last: _____
Applicant's Company Name: _____
Applicant's Address: (No. and Street) _____
Town: _____ State: _____ Zip Code _____
Bus: Phone: _____ Cell Phone: _____ Email: _____
License Type: _____ License #: _____ Exp Date: _____

Bldg Size (in sq ft): _____ Height of Bldg: _____ Estimated Cost: \$ _____
Zone _____ Lot # _____ Use Group _____ Type of Construction _____
Change of use: [] Yes [] No Change of occupancy: [] Yes [] No
If yes - Current Use/Occupancy _____ New Use/Occupancy _____

Description of Work: _____

BLANKET [] Yes [] No If yes - Estimated cost includes: ___ Electrical ___ Plumbing ___ HVAC

I hereby certify that I am the owner of the property which is subject of this application OR the authorized agent of the property owner; I agree to call at least 24 hrs. in advance for each inspection; I agree to uncover and expose any work which is covered or concealed without inspector's approval; I understand that when a permit is issued, it is a permit to proceed and grants no right to violate any code, ordinance, or statute, regardless of what may be shown or omitted on the submitted plans and specifications of any agreement with the official. All information contained within is true and accurate to the best of my knowledge and belief.

Signature: _____

FOR OFFICE USE ONLY

Fee Paid: \$ _____ [] Cash [] Check Receipt # _____ Permit #: _____

APPROVALS

Wetlands: [] N/A [] Approved _____ WEO
Zoning: [] N/A [] Approved _____ ZEO
Fire Marshal: [] N/A [] Approved _____
FVHD/MDC: [] N/A [] Approved - see attached

Building Official _____ Date _____

Location _____

TOWN OF EAST GRANBY SWIMMING POOL REQUIREMENTS

The building permit application must be accompanied by the following:

- Plot plan showing location of house, pool, fencing, enclosures with dimension and septic with distances to side & rear yards.
- Approval from the Farmington Valley Health District if required — need separate form.
- Plans of the structure stamped and sealed by an engineer — (In ground only)
- Distance to any wetland and/or watercourse.
- Permit fee.
- Per State Statute, clearance from the tax collector.

Pool installation requirements. This list is not all inclusive; please refer to pool packet.

- A 48" barrier will be provided to protect the pool access. Including a temporary fence for in-ground pools prior to filling.
- Access gates will be self closing and self latching - if less than 54" high, they shall be on the pool side and be protected within 18" of release mechanism).
- Doors providing direct access to the pool shall either have an alarm, a self closing/self latching device 54" above the floor, or a safety cover over the pool.
- No receptacles within 10' of pool. (locking type receptacle for pool equipment must be at least 5' from pool and GFCI protected).
- All metal parts of pool structure, fixed metal parts within 5' of pool, pump motors etc., shall be bonded with a minimum #8 solid copper wire.
- Convenience GFCI receptacle shall be provided between 10' and 20' from pool.
- Trench depth for 20 amp. circuit to pool equipment shall be 12" minimum.
- A surface pool alarm shall be installed pursuant to Public Act 99-140.
- All swimming pool pumps must be equipped with a time clock.
- Heated pools require a pool cover unless over 20% of the heating energy is from non-depletable sources.

REQUIRED SWIMMING POOL INSPECTIONS:

The following is a list of inspections that need to be performed prior to the continuation of work. Requests for inspections can be made by calling the Building Department at 860-653-3444.

- **TRENCH AND BONDING:** Electrical trench depth verification and bonding of pool and metal appurtenances including metal reinforcing for gunite pools.
- **FINAL ELECTRICAL:** Location of equipment and GFCI protection. Convenience outlet provided.
- **FINAL:** Swimming pool access protection must be provided before pool can be used.

Each swimming pool installation requires a Building and an Electrical permit. Additional permits and inspections are required for pool decks.

I have read and understand the requirements listed above.

Applicant Signature _____ Date _____

Homeowner Signature _____ Date _____

SWIMMING POOLS

THIS INFORMATION IS A GUIDE TO APPLICANT/OWNER TO THE COMMON ISSUES/QUESTIONS.
ALL WORK MUST BE DONE ACORDING TO THE STATE BUILDING CODES.

1. If the swimming pool is capable of holding 24 inches of water, the state building code requires a permit and code complaint barrier around the pool.
2. The top of the barrier shall be at least 48 inches above grade measured on the side of the barrier faces away from the pool.
3. Opening in the barrier shall not allow passage of a 4 inches diameter sphere.
4. Pedestrian access gates **shall open outward away from the pool and shall be self-closing and have a self-latching device.**
5. Generally release mechanism of the self-latching device is 54 inches from the bottom of the gate.
6. Where a wall of a dwelling serve as part of the pool barrier one of the following condition be met.
 - A. The pool shall be equipped with a power safety cover as required by the code
 - B. All doors with direct access to the pool through that wall shall be equipped with an alarm that produces an audible warning when the doors are opened. The alarm shall sound continually for a minimum of 30 seconds within 7 seconds after the door and its screen, if present, are opened and be capable of being heard throughout the house. Alarm shall be automatically reset under all conditions. For a single opening deactivation of alarm is permissible maximum of 15 seconds. The deactivation device shall be located at least 54 inches above the threshold of the door.
 - C. All doors with direct access to the pool through that wall shall be equipped with self-closing and self-latching device with the release mechanism located a minimum of 54 inches above the door threshold. Swinging door shall open away from the pool area.
7. Where an above-ground or on-ground pool structure is used as a barrier or where the barrier is mounted on the top of the pool structure and the means of access is a ladder or steps, then the ladder or steps shall be surrounded by a barrier as required by the code.
8. Pool grounding and bonding inspection is required before covered.